

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 127Date : 21.02-23

It is certified that an inspection team headed by Bibhudatta Tripathy
F.S.D. (Name of Officers
with designation) from Health & F.W - Deptt/CHO office (Name of
Department/Office) inspected the Prabhujee English Medium
School, V.S.S. Nagar, Bhubaneswar. (Name & Address of
the School) on 9.2.2023 and found that the Prabhujee English
Medium School, V.S.S. Nagar, Bhubaneswar (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.Signature with Seal : [Signature]Name : Dr. Deepak Kumar BeheraDesignation : Health Officer

To

Principal
Prabhujee English Medium
School, V.S.S. - Nagar, Bhubaneswar
(Name & Address of the Institution)

[Signature]
86

President
Kriya Yoga Foundation Trust
Kriya Yoga Ashram
VSS Nagar, Bhubaneswar-10

[Signature]
Principal
Prabhujee English Medium School
V.S.S. Nagar, Bhubaneswar



AQUACHEK
THE WATER TESTING FACILITY
FROM EUREKA FORBES LTD.
(AN ISO 9001:2015 CERTIFIED LABORATORY)



TEST REPORT

Report /ULR No : TC84332300000227F
Sample Receipt Date : 06.01.2023
Analysis Date : 06.01.2023 to 12.01.2023
Date of Report Issue : 12.01.2023
Customer Ref No / Date: NIL

Sample Code No : AWQRC/01/23/227
Sample Description : Water
Quantity : 1 litre
Sample Condition : Satisfactory & Sealed
Sample Type : Water Sample
Sample Detail : Marked As Drinking Water

ISSUED TO:-

Mr. A. K. Rath
Principal,
Prabhujee English Medium School,
VSS Nagar, Bhubaneswar,
Khurdha-751010


TEST RESULTS

PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
Sl No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Turbidity	NTU	BDL(DL=0.1)	1	IS:3025 (Part 10)-1984
2.	pH value	-	7.02	6.5-8.5	IS:3025 (Part 11)-1983
3.	Total Dissolved Solids	mg/l	112	500	IS:3025 (Part 16)-1984
4.	Total Hardness as CaCO ₃	mg/l	60	200	IS:3025 (Part 21)-2009
5.	Calcium as Ca ⁺⁺	mg/l	17.6	75	IS:3025 (Part 40)-1991
6.	Magnesium as Mg ⁺⁺	mg/l	3.8	30	IS:3025 (Part 46)-1994
7.	Total Alkalinity as CaCO ₃	mg/l	48	200	IS:3025 (Part 23)-1986
8.	Chloride as Cl ⁻	mg/l	26	250	IS:3025 (Part 32)-1988
9.	Free Residual Chlorine	mg/l	BDL(DL=0.2)	0.2	IS:3025 (Part 26)-2021
10.	Sulphate as SO ₄ ⁻	mg/l	13	200	IS:3025 (Part 24)-1986

BDL= Below Detection Limit. DL=Detection Limit.

Remarks:-

- 1) The Above water sample **conforms** to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted.
- 2) The results relate to item tested.


President
Kriya Yoga Foundation Trust
Kriya Yoga Ashram
VSS Nagar, Bhubaneswar-10


Principal
Prabhujee English Medium School
V.S.S. Nagar, Bhubaneswar

Lab Address

C-348, 3rd Floor, Ramphal Chowk
Sector 7, Dwarka, New Delhi
Mob No: 9868911295, 01141608075
Email ID: delhilab@eurekaforbes.com

Page 1 of 1

Corporate Office
B1/B2, 701, Marathon Innova, Off Ganpatrao Kadam Marg,
Lower Parel, Mumbai - 400013, India
Phone : +91-22-62601888, 48821700 / 09 / 13

Regd. Office
7, Chakraberia Road (South)
Kolkata-700025, India
Phone : +91-33-24755402


Authorized Signatory,
Vikas Bhardwaj
Quality Manager